

**PUBLIC WORKS COMMITTEE  
RESOLUTION #2016-32  
DETERMINING EMERGENCY IN WHICH  
PUBLIC HEALTH OR WELFARE OF CITY IS IN DANGER**

**WHEREAS**, a clarifier at the city wastewater treatment plant is in need of an unplanned repair as the main scum arm cannot rotate and remove scum from the water to the scum beach chamber; and

**WHEREAS**, while there are two clarifiers which are functioning, should one additional clarifier cease to function, there would be no backup clarifier resulting in a situation where a malfunction of the remaining clarifier would cause the wastewater treatment plant to operate in violation of its DNR permit, and which would permit the discharge of affluent without it receiving full treatment with resulting danger to the public health of the city.

**NOW, THEREFORE**, the Public Works Committee of the City of Milton does hereby resolve as follows:

The nonfunctioning of one of the clarifiers at the City of Milton wastewater treatment plant creates an emergency situation of threatened damage to the ability of the wastewater treatment plant to fully treat affluent prior to his discharge from the wastewater treatment plant, resulting in an emergency in which the public health of the city is in danger.

This resolution is being enacted pursuant to the provisions of Section 62.15 (1b), Wis. Stats. to provide that the provisions of Section 62.15 (1), Wis. Stats., do not apply to the repair of the nonfunctioning clarifier.

Approved by the Public Works Committee of the City of Milton this 4th day of October, 2016.

PUBLIC WORKS COMMITTEE

By: \_\_\_\_\_  
Chairperson